



JORDAN PETROLEUM REFINERY COMPANY LTD.

P.O. BOX 1079
AMMAN-JORDAN

Tender Overview: Industrial UPS Systems

Project: Design, Supply, Testing, and Commissioning of Industrial UPS Systems

Location: Jordan Petroleum Refinery Company (JPRC), Zarqa Site

Tender No.: 71 /2025

Key Technical Requirements

- **Supply:** 4 × 15kVA / 12kW Online Double-Conversion UPS units
 - **Configuration:** 2 independent N+1 parallel redundant systems
 - System A: U1 + U2
 - System B: U3 + U4
 - **Outputs:** Simultaneous 110VAC, 50Hz & 110VDC
 - **Battery Compatibility:** Must integrate with existing JPRC Ni-Cd battery banks
 - **DC Solution:** Dedicated DC-DC converter per UPS cabinet
 - **Environment:** Industrial-grade, harsh conditions (G3 corrosive, dust, sand, high temperature)
 - **Warranty:** 36 months comprehensive with on-site service & preventive maintenance
-

Scope of Work

1. Design & Engineering
 2. Supply of UPS Units & Accessories
 3. Factory Test
 4. Shipping & Delivery (DDP Zarqa Site, Jordan)
 5. Supervision of Installation
 6. Site Acceptance Test (SAT) & Commissioning
 7. Staff Training
 8. Warranty & After-Sales Support
-

Commercial & Delivery Terms

- **Pricing:** DDP Zarqa Site, Jordan (Incoterms 2020); alternative terms (FOB, CFR, CPT) subject to JPRC approval
 - **Bid Guarantee:** 5% of offer amount, valid 120 days
 - **Performance Guarantee:** 10% of contract value, valid 12 months post-commissioning
 - **Offer Validity:** Minimum 120 days from closing date
-

Important Notes

- Offers must be submitted **sealed, signed, and stamped** before **25 / 11 /2025, 12:30 PM (Jordan Local Time)**